STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	155479	A. BUILDING 01 , 02 B. WING _____	R 04/15/2011

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
KINGSTON CARE CENTER OF FORT WAYNE	1010 W WASHINGTON CENTER ROAD FORT WAYNE, IN 46825

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 02/28/11 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a). Survey Date: 04/15/11 Facility Number: 000522 Provider Number: 155479 AIM Number: 100267040 Surveyor: Amy Kelley, Life Safety Code Specialist At this PSR survey, Kingston Care Center of Fort Wayne was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies for the 100, 200 and 300 halls, and in compliance with Chapter 18 New Health Care Occupancies for the 400 hall and 410 IAC 16.2. This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, areas open to the corridors and all resident rooms on 400 hall. Single station battery operated smoke detectors have been installed in all resident rooms on 100, 200 and 300 halls. The facility has a capacity of 120 and had a census of 107 at the time of this survey.	{K 000}		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	155479	A. BUILDING 01 , 02 B. WING _____	R 04/15/2011

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
KINGSTON CARE CENTER OF FORT WAYNE	1010 W WASHINGTON CENTER ROAD FORT WAYNE, IN 46825

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	Continued From page 1 Quality Review by Lex Brashear, Life Safety Code Specialist-Medical Surveyor on 04/18/11.	{K 000}		